



Authorized Dealer
Window Film Products

Glass Checklist

Dealer Information

Code: 0329f3r2
Name: Segvel
Region: North America/APAC/LAA

Customer Information

Contact Name: Fernanda Gladys
Company Name: Casa das Peliculas
Address 1: Avenida Rio Branco, 416
Address 2: Rua Leoberto Leal, 01
City: FLORIANOPOLIS State: SANTA CATARINA
Zip: 88015-200
Phone: 48999603208 Fax:
Email: fernanda@angelocarin.com.br

Building Information

Glass Type: Clear Single Pane Size: 1080 x 1050
Number of Windows: 22
Pane Type (Single): Laminated
Thickness (Single): 8

Installation Conditions

Condition	Interior	Exterior
Window Age: 3 to 20 years	0.2	0.2
Window Location: Outside Wall	1	1
Glass Type: Clear Single Pane	0	0
Previous Glass Failure: No	N/A	N/A
Failure Percentage: 0	0	0
Indoor Shading: None	0	0
Indoor Structural Pocket: No	0	0
Outdoor Shading: 25% Horizontal	0.4	0.4
Window Framing: Aluminum or Steel Tubular Thick	0.2	0.2
Condition of Frame: Good	0	0
Sealant Type: Rubber Gasket	N/A	N/A
Condition of Sealant: Resilient	0	0
Outdoor Glazing Stop Color: Black	-0.2	-0.2
Heat Register Location: Directed Away from the Glass	0	0
Design Winter Temperature: Above 40F (4C)	-0.2	-0.2
High Altitude: Below 5000ft (1525m)	0	0
Adj. Self Reflecting Surface: None	0	0
Arching Window Type: None	0	0
Other Arching Window Type:	N/A	N/A
Window > 20 Square Feet: No	0	0
Total:	1.4000000000000001	1.4000000000000001

Expected Edge Stress

	Film	Approval	Film Stress Factor	Thermal Stress factor	Total PSI	Max PSI
Interior:	Silver P18	Yes	450	1.4000000000000001	630	5200.17
Exterior:	Silver P18	Yes	450	1.4000000000000001	630	5200.17

IMPORTANT NOTICE: This glass checklist is intended to help assess the compatibility of 3M Window Films with specific glazing constructions. The checklist is not intended to replace the customer's careful evaluation of 3M Window Film for the customer's intended application. 3M will not be liable for any loss or damage, whether direct, indirect, special, incidental or consequential resulting from or in any way related to the information contained in this checklist.